



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6102CP0515

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	TECO s.r.l. Via Santa Caterina, 8, I-25050 Camignone di Passirano (BS)
Distributor <i>Vertreiber</i>	TECO s.r.l. Via Santa Caterina, 8, I-25050 Camignone di Passirano (BS)
Product Category <i>Produktart</i>	stop valves for drinking water: ball valve (6102)
Product Description <i>Produktbezeichnung</i>	ball valve made of brass or red bronze for the drinking water installation with full bore
Model <i>Modell</i>	K4...
Test Reports <i>Prüfberichte</i>	supplement test: 20170221 from 21.02.2017 (TTR) supplement test: 20150915 from 15.09.2015 (TTR) supplement test: 20141203 from 03.12.2014 (TTR) KTW testing: KA 0215/14 from 24.05.2016 (TZW) hygienic testing: MO 065/16 from 31.12.2011 (WHY)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 13828 (01.12.2003) UBA METALLE (15.03.2017) UBA ELASTOM (16.03.2016) UBA KTW (07.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	03.12.2019 / 17-0083-WNR

7028-04-A-DE

11.12.2017 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
K4.0	pressure rating: PN 10 nominal diameter: DN 8	Connections: female thread Rp 3/8" (ISO 7-1)
K4.0; K4.1; K4.2	noise emission class: I pressure rating: PN 10 nominal diameter: DN 15	Connections: female thread Rp 1/2" (ISO 7-1); external thread G 3/4" (ISO 228-1); system "Fastec"
K4.0	noise emission class: II pressure rating: PN 10 nominal diameter: DN 20	Connections: female thread Rp 3/8" (EN 10226-1)

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

actuator: butterfly lever

DWG